

NIGHT LIGHTING REQUIREMENTS: "NL" DESIGNATION INDICATED NIGHT LIGHT ON UNSWITCHED CIRCUIT.

1. ONE NL BY SERVICE COUNTER, POS / CASHIER
2. ONE NL BY POS / CASHIER AT DRIVE THRU STATION IF APPLICABLE
3. ONE NL BY EACH EXIT DOORS IN DINNING ROOM □ BACK OF HOUSE
4. ONE NL BY MANAGER STATION

EQUIPMENT SCHEDULE	1
NOT TO SCALE	E-06



All ideas, designs, arrangement and plans indicated or represented by this drawing are the property of Panda Express Inc. and were created for use on this specific project. None of these ideas, designs, arrangements or plans may be used by or disclosed to any person, firm, or corporation without the written permission of Panda Express Inc.

ISSUE DATE:		
1st	ISSUE FOR PERMIT	02-15-17
2nd	ISSUE FOR BID	02-22-17

DRAWN BY:

[REDACTED]

PANDA PROJECT #: S8-17-D4968.

ARCH PROJECT #: 1703

Project No.
PE1703



**Kurzynske
& Associates**
CONSULTING ENGINEERS

**2900 Lebanon Pike
Suite 201
Nashville, Tennessee 37214**



PANDA EXPRESS
 entrance at Suwanee Gateway (in front of Lowe's)
 76 LAWRENCEVILLE-SUWANEE
 SUWANEE, GA

2200 TRUE WARM & WELCOME

E-001

ELECTRICAL SCHEDULES

TRUE WARM & WELCOME 2200